



阻燃释放后服务中断

https://kb-cn-stage.netapp.com/on-prem/ontap/OHW/OHW-KBs/Service_interruption_after_fire_suppre...

Updated: Wed, 22 Apr 2026 08:25:37 GMT

适用场景

- 所有NetApp内部存储解决方案
- 灭火排放或阻燃释放(包括由于错误警报)

问题描述

- 多个硬盘故障
- 机箱、磁盘架或其他组件可能温度过高
- 阻燃剂介质的潜在污染

'NetApp provides no representations or warranties regarding the accuracy or reliability or serviceability of any information or recommendations provided in this publication or with respect to any results that may be obtained by the use of the information or observance of any recommendations provided herein. The information in this document is distributed AS IS and the use of this information or the implementation of any recommendations or techniques herein is a customers responsibility and depends on the customers ability to evaluate and integrate them into the customers operational environment. This document and the information